



MegaWatt Solutions
Värmepumpberäkning

Energy calculations **Brf Trasten**

H Adolfsson
Trastgatan 1

Kenneth Persson, MegaWatt Solutions Nordic AB

Summary

Energy/power consumption

Energy for heating	1401000 kWh
Energy for hot water	900000 kWh
Building's power req for heating at DOT	481,0 kW

After heatpump installation

6 * HPM72-R290	
Suggested number of holes and depth	36 * 276 m
Energy from heat pump totally	2291828 kWh/year
Auxiliary energy	9172 kWh/year
Energy to purchase	677327 kWh/year
Energy savings	1623673 kWh/year

Installation

City	Mellerud
Avg. outdoor temp	7,0 °C
Dim. Outdoor Temp (DOT)	-15,6 °C
Room temp curr	21,0 °C
Heating stops at	18,0 °C
Forward temp at DOT	60 °C
Return temp at DOT	45 °C
Specific energy consumption	69 kWh/m ²

Performance data

Total energy production	2301000 kWh/year
Total Energy Consumption	668155 kWh/year
Auxiliary energy for heating	9172 kWh/year
Auxiliary energy for hot water	0,00 kWh/year
Power coverage at DOT	78,3 %
Energy coverage heat pump	99,6 %
Yearly performance factor (heat pump)	3,43
Max heating power of HP at DOT	310,0 kW

The calculations are based on a simplified model and that the given indata is correct. Presented results should not be considered as a promise.

Meteorological data from Klimatfiler 1981-2010 för Energiberäkning Sveby-SMHI.

Indata

Project Data

Project name	Brf Trasten	Notes
Building	Brf Trasten	
Company		

Energy/power consumption

Net Energy Consumption	2301000 kWh	Calculation method	Known energy consumption
Water heating	900000 kWh	Energy (efficiency)	<i>Net (gross)</i>
Room temp curr	21,0 °C	District heating ($\eta=100\%$)	2301000 (2301000) kWh
Selfheating	3,0 K		
Heated Area A(temp)	9780 m ²		

Installation

Heatpump	6 * HPM72-R290	City	Mellerud
Two-step DHW production	2 units	Dim. Outdoor Temp (DOT)	-15,6 °C
Source	Bore hole	Avg. outdoor temp	7,0 °C
Type of rock	Normal	Degreehours	97866
Conductivity	3,30 W/m-K	Hot water boiler temp	60 °C
Geometry	Line / L-shape		
Max depth	280 m		
Depth to rock	10 m		
Horiz. distance between holes	15 m		
Spreading angle of holes	0,0 °		
Auxiliary power	172,0 kW		

Operation Parameters

Forward temp at DOT	60,0 °C	Avg temp of incoming brine	0,5 °C
Return temp at DOT	45,0 °C	Avg temp diff brine in/out	3,0 °C

Calculation Results

Building's energy req for heating and hot water	2301000 kWh	Theoretic active bore hole depth	7869 m
Building's power req for heating at DOT	481,0 kW	Geometrically adapted active bore hole depth	9565 m
Max heating power of HP at DOT	310,0 kW	Suggested number of holes and depth	36 * 276 m
Avg. power HW (kW)	102,7 kW	Max cooling power HP	308,4 kW
Max heating power of HP (hot water) at DOT	193,9 kW	Max brine flow	24,5 l/s
Power coverage at DOT	78,3 %	Total cooling energy HP	1623673 kWh/year
Energy coverage heat pump	99,6 %		
Max electric power for heat pump and auxiliary heat	320,4 kW		
HP maximum power (at -6,0 °C outdoor)	343,6 kW		
Time of utilization ¹	6671 h		
HP operation (heating)	4359 h		
HP operation (hot water)	4641 h		
Yearly performance factor (heat pump)	3,43		
Energy factor ²	3,40		
Energy from heat pump for heating	1391828 kWh/year	Electricity to heat pump for heating	328839 kWh/year
Auxiliary energy for heating	9172 kWh/year	Auxiliary energy for heating	9172 kWh/year
Energy from heat pump for hot water	900000 kWh/year	Electricity to heat pump for hot water	339317 kWh/year
Auxiliary energy for hot water	0 kWh/year	Auxiliary energy for hot water	0 kWh/year
Total energy production	2301000 kWh/year	Total Energy Consumption	677327 kWh/year
		Of which Electricity	668155 kWh/year
		District heating ($\eta=100\%$) as auxiliary	9172 kWh/year
		Specific energy consumption	69 kWh/m ²

Energy savings

1623673 kWh/year

Gross savings on purchased energy **1623673 kWh/year**


¹ Time of utilization is the ratio of total energy produced for heating by the HP and the maximum power of the HP

² Energy factor is the ratio between useful and total purchased energy, auxiliary included.


The calculations are based on a simplified model and that the given indata is correct. Presented results should not be considered as a promise.

Meteorological data from Klimatfiler 1981-2010 för Energiberäkning Sveby-SMHI.

Energy consumption/mon




Energy production/mon




The calculations are based on a simplified model and that the given indata is correct. Presented results should not be considered as a promise.
Meteorological data from Klimatfiler 1981-2010 för Energiberäkning Sveby-SMHI.


Electricity consumption



Energy production



Consecutive Graphs



The calculations are based on a simplified model and that the given indata is correct. Presented results should not be considered as a promise.
Meteorological data from Klimatfiler 1981-2010 för Energiberäkning Sveby-SMHI.